



**WASHINGTON STATE**  
UNIVERSITY

**Addendum No. 4**  
**March 30, 2023**

**WSU Sunrise Orchard Irrigation Line and Pond**  
Washington State University  
Wenatchee, WA

Project No. 1262-2020  
Washington State University  
Facilities Services, Capital

**Addendum No. 4  
3/30/2023**

**WSU Sunrise Orchard Irrigation Line and Pond  
Washington State University  
Wenatchee, WA**

**Bid Date: April 5, 2023**

1. This Addendum forms a part of the Contract Documents and modifies the original Bidding Documents dated February 9, 2023, and any prior addenda, as noted below.
2. Please acknowledge receipt of this addendum on the Form of Proposal.

This Addendum consists of two total pages and no attachments.

**Changes to prior Addenda:**

From Addendum 2: Bidder Questions: Correction to the WSU Response to Question No. 8

Q 8R. May HDPE IPS be substituted for DIP?

WSU Response: bidders should bid based upon **High Density Polyethylene - Ductile Iron Pipe Size** for this project.

**Changes to Bidding Requirements:**

None

**Changes to Specifications:**

None

**Changes to Drawings:**

None

END OF ADDENDUM No. 4